



December 1, 2011

Gregory E. Hazel  
Village of Rantoul  
200 West Grove Avenue  
Rantoul, IL 61866

Re: Requests for Information, Section 09-00102-00-PV, Murray Rd/US 136

Dear Sir:

Per our earlier conversation, we have received a request Requests for Information (RFI) asking for clarification on one item. What follows is a list of the questions and our suggested responses:

1. Is a profilograph required for this project?

Surface testing for this project will be done in strict accordance with Article 420.10 and Article 407.09 of the Standard Specifications. We read those to say that surface testing may be done with a 16' straight-edge.

Please review and comment on this question and the suggested responses. Thank very much for your attention.

Sincerely,

MSA Professional Services

Tom Okite  
Project Engineer

---

**Offices in Illinois, Iowa, Minnesota, and Wisconsin**

201 WEST SPRINGFIELD AVENUE, SUITE 300 • CHAMPAIGN, IL 61820  
217.352.6976 • 877.352.0081 • FAX: 217.356.0570

www.msa-ps.com