

# Village of Rantoul

## Copper & Lead Tests North Drive


Maximum Containment Level:

Copper = 1300 ug/L

Lead = 15 ug/L

\*\*\*2014 Aerial Image provided by  
Champaign County GIS Consortium

0 40 80 160 240  
Feet



Village of Rantoul  
Public Works Dept.  
200 W. Grove Avenue  
Rantoul, IL 61866  
(217) 892-2178



07/20/2016

NOTE: This product was prepared for informational  
and general reference purposes. The Village of Rantoul  
shall assume no liability for any error, omissions, or  
inaccuracies in the information provided.

1053 North		
Year	Copper (ug/L)	Lead (ug/L)
2014	180	1
2011	48	1
2008	19	1

1065 North		
Year	Copper (ug/L)	Lead (ug/L)
2014	130	1.4
2011	100	1.8
2008	14	1

1033 Cambridge		
Year	Copper (ug/L)	Lead (ug/L)
2014	40	1
2011	68	1
2008	38	1

1052 Lancaster		
Year	Copper (ug/L)	Lead (ug/L)
2014	22	1
2011	35	1
2008	21	1

1061 Pinecrest		
Year	Copper (ug/L)	Lead (ug/L)
2014	N/A	N/A
2011	50	1
2008	12	1

1037 Pinecrest		
Year	Copper (ug/L)	Lead (ug/L)
2014	32	1
2011	39	1
2008	9.1	1

1055 Pinecrest		
Year	Copper (ug/L)	Lead (ug/L)
2014	33	1
2011	N/A	N/A
2008	N/A	N/A

1043 Pinecrest		
Year	Copper (ug/L)	Lead (ug/L)
2014	44	1
2011	19	1
2008	23	1

1062 Pinecrest		
Year	Copper (ug/L)	Lead (ug/L)
2014	16	1.1
2011	36	1
2008	30	1