

Village of Rantoul

Copper & Lead Tests Oakcrest


Maximum Containment Level:

Copper = 1300 ug/L

Lead = 15 ug/L

***2014 Aerial Image provided by
Champaign County GIS Consortium

0 40 80 160 240
Feet



Village of Rantoul
Public Works Dept.
200 W. Grove Avenue
Rantoul, IL 61866
(217) 892-2178



07/20/2016

NOTE: This product was prepared for informational
and general reference purposes. The Village of Rantoul
shall assume no liability for any error, omissions, or
inaccuracies in the information provided.

905 Oakcrest		
Year	Copper (ug/L)	Lead (ug/L)
2014	21	1
2011	12	1
2008	8.3	1

574 Hazelcrest		
Year	Copper (ug/L)	Lead (ug/L)
2014	14	1
2011	13	1
2008	15	1

634 Briarcliff		
Year	Copper (ug/L)	Lead (ug/L)
2014	26	1
2011	22	1
2008	16	1

1101 Lancaster		
Year	Copper (ug/L)	Lead (ug/L)
2014	42	1.1
2011	62	1
2008	11	1

1031 Thomas		
Year	Copper (ug/L)	Lead (ug/L)
2014	5.9	1
2011	5.6	1
2008	20	1

1025 Thomas		
Year	Copper (ug/L)	Lead (ug/L)
2014	36	1
2011	30	1
2008	18	1

