

ADDENDUM NO. 1

Issued to: All RFP Document Holders of Record
Date: June 13, 2019
Project Name: Final Clarifier Improvements
Village Bid No.: VRNTL-20-R-03

This Addendum forms a part of the Contract described above. The original Contract Documents and any prior Addenda remain in full force and effect except as modified by the following which shall take precedence over any contrary provisions in the prior documents.

Please revise the following section to read:

3) Specifications

i) Description of Work

- (a) The scope of this section shall include furnishing all materials, tools, equipment, and labor for successful installation, including demolition and removal work, of two (2) fiberglass reinforced plastic (FRP) weir and scum baffle systems, one for each 85' clarifier tank. **The weir and scum baffle systems shall include FRP Launder Troughs; Support brackets; Stainless steel fasteners and connections.**

Please note that there is no change in the Bid Opening of June 26, 2019 at 2:30pm

Each Vendor shall acknowledge receipt of this Addendum by affixing his signature below and by attaching this Addendum to their proposal. *Failure to acknowledge any Addendum shall be considered sufficient cause for rejection of your proposal.*

ACKNOWLEDGEMENT

The undersigned acknowledges receipt of this Addendum and the Proposal submitted is in accordance with information, instructions and stipulations set forth herein.

Vendor:

By:

Date:
