

ORDINANCE NO. 2611

**AN ORDINANCE
AMENDING SECTION 3404.2.9.5.1 OF THE FIRE CODE
AS ADOPTED BY SECTION 10-267 OF THE RANTOUL CODE**

**VILLAGE OF RANTOUL
CHAMPAIGN COUNTY, ILLINOIS**

CERTIFICATE OF PUBLICATION

Published in pamphlet form this 11th day of June, 2019, by authority of the President and Board of Trustees of the Village of Rantoul, Champaign County, Illinois.

A handwritten signature in black ink, appearing to read "Mike Graham", written over a horizontal line.

Village Clerk

ORDINANCE NO. 2611

AN ORDINANCE
AMENDING SECTION 3404.2.9.5.1 OF THE FIRE CODE
AS ADOPTED BY SECTION 10-267 OF THE RANTOUL CODE

BE IT ORDAINED BY THE PRESIDENT AND THE BOARD OF TRUSTEES OF THE VILLAGE OF RANTOUL, ILLINOIS, as follows:

Section 1. Adoption. Section 3404.2.9.5.1 of the Fire Code, entitled “Locations where above-ground tanks are prohibited”, as adopted by Section 10-267, entitled “Additions, amendments, insertions and deletions”, of Article VIII, entitled “FIRE CODE”, of Chapter 10, entitled “Buildings and Building Regulations”, of the Rantoul Code, as supplemented and amended, be and the same is hereby further amended as set forth in the title, headings and text thereof as attached hereto and hereby incorporated herein by this reference thereto.


Section 2. Effective Date. The provisions of this Ordinance shall become effective following its passage, approval and publication as required by law.

Section 3. Conflict. All ordinances or parts of ordinances which are in conflict with the provisions of this Ordinance are, to the extent of such conflict, hereby repealed.

Section 4. Publication. The Village Clerk is hereby authorized and directed to cause this Ordinance to be published in pamphlet form.


This ordinance is hereby passed, the “ayes” and “nays” being called, by the concurrence of a majority of the Trustees of the Village then holding office at a regular meeting on the date set forth below.

PASSED this 11th day of June, 2019.



Village Clerk

APPROVED this 11th day of June, 2019.



Village President



Sec. 10-267. - Additions, amendments, insertions and deletions.

The following sections of the Fire Code are hereby revised as follows:

* * * * *

ADD Section 3404.2.9.5.1 Locations where above-ground tanks are prohibited: The geographic limits in which the storage of Class I and Class II liquids in above-ground tanks outside of buildings is prohibited is hereby specified to be any area other than an area zoned for industrial, commercial or airfield use under the Zoning Ordinance of the Village, provided, however, that if located in an area zoned for commercial use, including any use permitted in the C-4 Commercial/Industrial District, the capacity of any such above-ground tank shall be limited to a maximum capacity of 3,000 water gallons unless any such above-ground tank or tanks are used exclusively for the storage of a Class II liquid to provide fuel for back-up power generation, in which event a separate above-ground tank with maximum capacity of up to 3,000-water gallons shall be permitted for each back-up generator up to a maximum of six (6) generator(s).